



NOT to be distributed outside of FMGlobal except by CUSTOMER.

# APPROVAL REPORT

**KIDDE FM-200® ADS SERIES AND FENWAL FM-200®  
PHOENIX ENGINEERED, UNBALANCED FIRE  
EXTINGUISHING SYSTEMS – (MODIFICATIONS) – 675  
lb (306 kg) AND 1010 lb (458 kg) STORAGE  
CONTAINERS WITH NITROGEN DRIVER SETS AND  
THREE-WAY DIRECTIONAL VALVES ASSEMBLIES**


**Prepared for:**

**Kidde-Fenwal, Inc.  
400 Main Street  
Ashland, MA 01721**

**Project Identifier 3015461**

**Class 5612**

**Date of Approval: May 21, 2003**

**Authorized by:**   
Roger L. Allard, Group Manager

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102  
Norwood, MA 02062

Page 1 of 70

An  Enterprise